



FLORIDA FPM PROCESSING MACHINERY, INC.

Office: 904-701-1843
 1-800-291-4003
 (941) 701-0855
 2820 Parkway St.
 Lakeland, FL 33811

- General Notes — Concrete**
1. CONCRETE SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH OF 4000 PSI IN 28 DAYS. CEMENT SHALL BE TYPE II.
 2. REINFORCING STEEL SHALL CONFORM TO ASTM A-615, GRADE 60 (MIN.) WELDED WIRE
 3. FORMING SHALL CONFORM TO ASTM STD. A183.
 4. EXIST. FTG. HOLES 6" C/C, 2" FROM BOT. & TOP OF FTG.
 5. REF. IS TO THE SOILS REPORT #01-55-9770
- DATE: JUNE 29, 01 PREPARED BY ARDMAN & ASSOC., TPA, FL
- BEFORE INSTALLING ANY FOUNDATIONS:
- A. CSE-ENGINEER/ CONTRACTOR MUST PREPARE THE SITE PER RECOMMENDATIONS IN APPENDIX B
 - B. CONTRACTOR/ ENGINEER MUST SUBMIT ALL THE ABOVE TEST RESULTS FOR FPM'S APPL.
 - C. ARDMAN NEEDS NOT BE PRESENT DURING FOUNDATION INSTALLATION.

REV.	ISSUE	BY	DATE	DWG. NO.	REV.